



December 2, 2021

(306) 741-7718

Via Email: [beechy@sasktel.net](mailto:beechy@sasktel.net)

Village of Beechy  
Box 153  
BEECHY SK S0L 0C0

Attention Waterworks Owner/Operator:

**RE: Precautionary Drinking Water Advisory for the Village of Beechy – Rescinded**

The Water Security Agency (WSA) is satisfied with *two sets of* negative bacteriological sampling and adequate disinfection residuals and turbidity values from samples that have been collected from the water distribution system following the recent localized *extended* waterworks system depressurization (***1<sup>st</sup> Street East, between 2<sup>nd</sup> Ave and 4<sup>th</sup> Ave North***). Therefore, effective immediately the WSA is rescinding the **“Precautionary Drinking Water Advisory”** for the remainder of the residents and users of the *Village of Beechy’s* water supply.

For further information, please do not hesitate to contact the undersigned at (306) 741-7718 or [Scott.Klippenstein@wsask.ca](mailto:Scott.Klippenstein@wsask.ca).

Sincerely,

A handwritten signature in black ink, appearing to read "Scott Klippenstein".

Scott Klippenstein – A.Sc.T.  
Environmental Project Officer

cc: Roger Miller, Manager, E&MMS Division, WSA (email)  
Water Advisories, Water Security Agency  
Saskatchewan Health Authority, Rosetown Office